



# **Flower Pollination Based Load Shedding for Enhancing Voltage Stability in Distribution Networks**

P. Aravindhababu

Professor, Department of Electrical Engineering, Annamalai University, Annamalainagar, Tamilnadu, India

**ABSTRACT:** Voltage instability has become a major issue in distribution networks due to ever-rising load demands. As the networks are operating in stressed condition, even a simple disturbance may collapse the network. The simplest way to bring the network to a stable operating zone is to perform load shedding. This paper presents a methodology involving flower pollination based optimization (FPO), inspired from the pollination process of plants, for finding appropriate node locations for load shedding and the quantity of sheddable load with a view of bringing the network to a stable voltage region. It employs a voltage stability index for assessing the nearness of the current operating point to the voltage collapse region. The method not only enhances the voltage stability but also improves the voltage profile. It presents the results of the proposed method for 33-node distribution network to exhibit its effectiveness.

**KEYWORDS:** distribution networks; voltage collapse; flower pollination optimization; voltage stability index.

## **I. INTRODUCTION**

The ever-rising load demand at distribution level drives the network towards the verge of voltage collapse (VC), which is featured by a slow voltage drop initially and a rapid voltage fall after some time. This VC is generally initiated by some kind of disturbances in terms of changes in real and/or reactive load powers. When the network is operating near VC region, the prime objective of the network engineer is to bring the network to a stable voltage region by switching capacitor banks, bringing standby DG units on-line, changing the transformer tap settings and controlling the other reactive power sources. If the network still remains in the voltage collapse region, the last priority is the load shedding. Smaller amount of load shedding may not be effective, while at the same time, larger amount of load shedding affects more number of consumers. The load shedding should be performed in an optimal way with least amount of load shedding at the most appropriate node locations in order to bring the network far away from the VC point [1].

Over the years, extensive research has been performed on under-frequency load shedding [2-5] and load shedding on transmission systems for avoiding VC [6-8], but a little focus is oriented towards load shedding of distribution networks for avoiding VC [9-11]. The voltage stability of distribution networks has become a prime topic of research in recent years and therefore several voltage stability indices to assess the distance between the current operating point to the VC region were suggested [12].

Flower pollination based optimization (FPO), inspired from the pollination process of plants, was suggested for solving optimization problems [13]. This paper attempts to apply FPO in solving the optimal load shedding problem of distribution networks. The method employs the voltage stability index (VSI) suggested in [12]. The results of the proposed method for 69-node system is included in this paper.

## **II. PROBLEM FORMULATION**

The load shedding problem can be formulated as an optimization problem involving the VSI, suggested in [12]. The VSI assesses the operating state of the distribution network and varies between unity at no load and zero at VC point. The node locations and amount of sheddable load are considered as the problem variables and optimized to bring the lowest VSI of the network to lie above a level of a critical threshold value. The problem can be formulated as



# International Journal of Advanced Research in Electrical, Electronics and Instrumentation Engineering

(An ISO 3297: 2007 Certified Organization)

Vol. 5, Issue 3, March 2016

$$\text{Maximize } \Phi(x) = \left\{ \min(VSI_m) - VSI^{th} \right\} + w \left\{ 1 / 1 + \sum_{j=1}^{nsn} psP_j \right\} \quad (1)$$

Subject to

$$P_{Gm} - P_{Dm} - P_m(V, \delta) = 0 \quad (2)$$

$$Q_{Gm} - Q_{Dm} - Q_m(V, \delta) = 0 \quad (3)$$

$$V_m^{\min} \leq V_m \leq V_m^{\max} \quad (4)$$

Where  $VSI_m$  represents the VSI at node-m and is calculated by

$$VSI_m = \left[ 2 \frac{V_m}{V_k} \cos(\delta_k - \delta_m) - 1 \right]^2 \quad (5)$$

- $V_k$  : voltage magnitude at node-  $k$
- $\delta_k$  : voltage angle at node- $k$
- $r_{km} + jx_{km}$  : resistance and reactance of feeder-  $m$
- $P_{km} + jQ_{km}$  : real and reactive powers at the receiving end of feeder-  $m$
- $P_{Gm} + jQ_{Gm}$  : real and reactive power generation at node-  $m$
- $P_{Dm} + jQ_{Dm}$  : real and reactive power demand at node-  $m$
- $psP_j + jpsQ_j$  : percentage of sheddable real and reactive power load at chosen node location-  $j$
- $nsn$  : number of sheddable nodes

### III. PROPOSED METHOD

The proposed method employs FPO in solving the load shedding problem. It requires representation of problem variables in the form of flowers and formation of a fitness function. Each flower [13] in the load shedding problem is modelled to represent the sheddable node locations ( $snL$ ) and the percent of sheddable load ( $psP$ ) at each node as

$$flower_i = [snL_1, snL_2, \dots, snL_{nsn} \quad psP_1, psP_2, \dots, psP_{nsn}] \quad (6)$$

The fitness function is formed as

$$\text{Maximize } F = \left\{ \min(VSI_m) - VSI^{th} \right\} + w \left\{ 1 / 1 + \sum_{j=1}^{nsn} psP_j \right\} \quad (7)$$



# International Journal of Advanced Research in Electrical, Electronics and Instrumentation Engineering

(An ISO 3297: 2007 Certified Organization)

Vol. 5, Issue 3, March 2016

Initially a population of flowers is randomly generated and the fitness of each flower is calculated using Eq. (7) with a chosen threshold value ( $L^{th}$ ). The global or local pollination is stochastically performed to all the flowers in the population, thereby generating a new set of flowers. The process of generating a new set of flowers is represented as an iteration, which is continued by considering the population obtained in the previous iteration as the initial population for next iteration. The FPO iterative process of generating new population can be terminated after a fixed number of iterations. The flower having the best fitness function value is considered as the optimal solution after convergence. The pseudo code for FPO is available in [13].

## IV. SIMULATION RESULTS

The proposed method (PM) is tested on a 69-node distribution network, whose data are available in [14]. The distribution power flow proposed in [15] is used in this study. The load demand at all nodes are increased by a load factor of 1.2, 1.4 and 1.6 and the threshold value for VSI is chosen as 0.85. The number of nodes for load shedding is heuristically chosen as 4.

The results comprising the lowest VSI ( $VSI^{LOW}$ ), lowest voltage magnitude ( $VM^{LOW}$ ), the sheddable node locations, and percent of sheddable power at chosen nodes are presented in Table 1. At base-case, that is when the load factor is 1.0, the lowest value of VSI is 0.8874, which is higher than the threshold value, and indicates that the operating point is far away from the VC zone. When the load is increased by a factor 1.2, the lowest value of VSI is 0.8403 and indicates that the operating point is nearer to the VC point, and a small disturbance in the network may initiate VC. The PM chooses nodes 6,8,14 and 60 as the most appropriate nodes and also instructs to shed 18, 23, 19 and 29% of loads at the respective nodes to bring the network away from the VC region. After load shedding, the lowest VSI comes to a safe value of 0.8612 from the value of 0.8403. It can also be seen that the lowest VM is improved from 0.9057 to 0.9072. Similar improvement can be seen for the results with load factors of 1.4 and 1.6.

It is very clear from the results that the PM performs optimal load shedding and improves both the voltage stability and voltage profile.

Table 1  
Results of proposed load shedding

Load Factor	Nodes for Load Shedding	Percent of Sheddable load				Before Load Shedding		After Load Shedding	
						$VSI^{LOW}$	$VM^{LOW}$	$VSI^{LOW}$	$VM^{LOW}$
1.0	---	---	---	---	---	0.8874	0.9330	0.8874	0.9335
1.2	6,8,14,60	18	23	19	29	0.8403	0.9057	0.8612	0.9072
1.4	5,8,10,59	32	43	40	29	0.8310	0.8765	0.8599	0.9033
1.6	6,7,10,61	43	58	67	53	0.7990	0.8449	0.8586	0.8996

## V. CONCLUSION AND FUTURE WORK

Flower Pollination Optimization (FPO), inspired from the pollination process of plants, searches for optimal solution for multimodal optimization problems. A methodology using FPO was developed for solving load shedding problem, which is a complex, mixed integer and non-linear optimization problem. The PM was applied on a 69-node distribution network with four load levels and the results were found to improve both voltage stability and voltage profile. The load shedding problem can be modified to include the other objectives such as improving the voltage profile and reducing the network loss in future and solved using FPO. The other methodologies such as reconfiguration and DG placement can be combined with load shedding and studied.



# International Journal of Advanced Research in Electrical, Electronics and Instrumentation Engineering

(An ISO 3297: 2007 Certified Organization)

Vol. 5, Issue 3, March 2016

## ACKNOWLEDGEMENTS

The author gratefully acknowledges the authorities of Annamalai University for the facilities offered to carry out this work

## REFERENCES

1. C.W. Taylor, 'Power System Voltage Stability', McGraw-Hill, Inc., 1994.
2. VN Chuvyichin, NS Gurov, SS Venkata and RE Brown, 'An adoptive approach to load shedding and spinning reserve control during underfrequency conditions', IEEE Trans. on Power Systems, Vol. 11, No. 4, pp. 1805-1810, 1996.
3. S-J. Huang and C-C. Huang, 'An adoptive load shedding method with time-based design for isolated power systems', Electrical Power and Energy Systems, Vol. 22, No. 1, pp. 51-58, 2000.
4. C T Hsu, H J Chuang and C S Chen, 'Artificial neural network based adaptive load shedding for an industrial cogeneration facility', Industry Applications Society Annual Meeting-IAS'08, pp. 1-8, 5-9 Oct 2008
5. D Mingchui, L Chinwang and W Chikong, 'Adaptive under-frequency load shedding', Tsinghua Science and Technology, Vol. 13, No. 6, pp. 823-828, 2008.
6. M Z El-Sadek, G A Mahmoud, M M Dessouky and W I Rashed, 'Optimum load shedding for avoiding steady state voltage instability', Elect Power System Research, Vol. 50, No. 2, pp. 119-123, 1999.
7. FM Echavarren, E Lobato and L Rouco, 'A corrective load shedding scheme to mitigate voltage collapse', Electrical Power and Energy Systems, Vol. 28, No. 1, pp. 58-64, 2006.
8. N Sadati, T Amraee and AM Ranjbar, 'A global particle swarm based simulated annealing optimization technique for under-voltage load shedding problem', Applied Soft Computing, vol.9 (2), pp. 652-657, 2009.
9. G Mohan and P Aravindhbabu. (2010), 'Load shedding algorithm for avoiding voltage collapse in distribution systems', Journal of Electrical Engineering, Vol. 10, No. 1, pp. 1-5.
10. G Mohan and P Aravindhbabu, 'Load shedding algorithm for avoiding voltage instability in distribution systems', International Journal of Power Engineering and Green technology, ISSN:0976-6286, 1(1): 39-45, 2010.
11. M Arun and P Aravindhbabu, 'Load shedding algorithm for avoiding voltage collapse in distribution systems', International Journal of Integrated Energy Systems, Vol. 3, No. 1, pp. 57-63, 2011.
12. M H Haque, "A linear voltage stability margin for radial distribution systems", Proc. IEEE PES General Meeting, Montreal, Canada, pp. 1-6, June-2006.
13. Yang X. S, 'Flower Pollination Algorithm for Global Optimization', Unconventional Computation and Natural Computation, Lecture Notes in Computer Science, Vol. 7445, pp. 240-249, 2012.
14. S Sivanagaraju, N Visali, V Sankar and T Ramana, 'Enhancing voltage stability of radial distribution systems by network reconfiguration', Electric power components and systems, Vol. 33, No. 5, pp. 539-50, 2004.
15. P Aravindhbabu and R Ashokkumar, 'A fast decoupled power flow for distribution systems', Electric Power Components and Systems, Vol. 36, No. 9, pp. 932-940, 2008.