



# **Dc Component Minimization by Integral Method in Grid Connected Photovoltaic Inverter System**

Y.Rajitha<sup>1</sup>, G. Veera Shankara Reddy<sup>2</sup>, M. Naveen Babu<sup>3</sup>

M.Tech, Dept. of EEE, Tadipatri Engineering College, Affiliated to JNTUA, AP, India<sup>1</sup>

Assistant Professor, Dept. of EEE, Tadipatri Engineering College, Affiliated to JNTUA, AP, India<sup>2</sup>

Assistant Professor and HOD, Dept. of EEE, Tadipatri Engineering College, Affiliated to JNTUA, AP, India<sup>3</sup>

**ABSTRACT:** The dc component can cause line-frequency power ripple, dc-link voltage ripple, and a further Second-order harmonic in the ac current. This paper has proposed an effective solution to minimize the dc component in three-phase ac currents and developed a software-based approach to mimic the blocking capacitors used for the dc component minimization, the so-called virtual capacitor. The “virtual capacitor” is achieved by adding an integral of the dc component in the current feedback path. A method for accurate extraction of the dc component based on double time integral, as a key to achieve the control, has been devised and approved effective even under grid frequency variation and harmonic conditions. A proportional-integral-resonant controller is further designed to regulate the dc and line-frequency component in the current loop to provide precise control of the dc current.

## **I. LITERATURE REVIEW AND RELATED WORKS**

The elimination of the output transformer from grid-connected photovoltaic (PV) systems not only reduces the cost, size, and weight of the conversion stage but also increases the system overall efficiency. However, if the transformer is removed, the galvanic isolation between the PV generator and the grid is lost. This may cause safety hazards in the event of ground faults. Various inverter topologies are presented, compared, and evaluated against demands, lifetime, component ratings, and cost. Finally, some of the topologies are pointed out as the best candidates for either single PV module or multiple PV module applications[1]. The accuracy of the DC current sensor then becomes important to achieving this. A scheme is proposed in which DC link current sensing and current control are used to minimize the output DC current component. Current controllers are affected by errors associated with nonlinearity and offset in the current sensors[4]. Transformers operating under saturation conditions present increased power losses, overheating and distorted current waveforms. Since a DC current component causes a small DC voltage component drop across the parasitic resistance of the distribution grid conductors, canceling the DC voltage component at the Point of Common Coupling (PCC) implies the compensation of the DC current injection by electric loads or grid connected converters connected at the same PCC[5]. The main goal is to ensure a reduction of the switching frequency ripple at a reasonable cost and, at the same time. The experimental results demonstrate the effectiveness of the design procedure both of the LCL-filter and of the controllers. The performance of the overall system is good both in the low and high frequency ranges[3].

## **II. EXISTING SYSTEM**

There are many problems related to Transformerless structures, like dc element within the electrical converter output (grid) current, ground run current (due to common-mode voltage and parasitic capacitance), and also the voltage-level mate between the electrical device (inverter) and grid. Among them, the dc element will have an effect on the normal system operation and cause safety issues. Standards have so been established in several countries to limit the extent of the dc element

# International Journal of Advanced Research in Electrical, Electronics and Instrumentation Engineering

(An ISO 3297: 2007 Certified Organization)

Website: [www.ijareeie.com](http://www.ijareeie.com)

Vol. 6, Issue 2, February 2017

## DISADVANTAGE OF EXISTING

### SYSTEM

The dc component can have negative impacts on the power system in the following ways [9], [11]:

- 1) The dc component can affect the operating point of the transformers in the power system. The transformer cores are driven into unidirectional saturation with consequent larger excitation current. The service lifetime of the trans-former is reduced as a result with further increased hysteresis and eddy current losses and noise.
- 2) The dc component can circulate between inverter phase legs as well as among inverters in a paralleled configuration. The dc component circulation affects the even current and loss distribution among paralleled inverters.
- 3) The dc component injected to the grid can affect the nor-mal operation of the loads connected to the grid, for example, causing torque ripple and extra loss in ac motors.
- 4) The corrosion of grounding wire in substations is intensified due to the dc component.

## III. PROPOSED SYSTEM

### A. VIRTUAL CAPACITOR CONCEPT OF SINGLE-PHASE GRID-CONNECTED PV INVERTERS

One way to block the dc component is to put a capacitor  $C$  in series with the ac side of the inverter. However, in order to reduce the capacitive reactance at other frequencies, the capacitor value needs to be large, which increases the size and cost of the system. This series capacitor may also affect the system dynamic response and reduce transmission efficiency. Nevertheless, the physical capacitor can be re-placed by software-based method and advanced control strategy which mimics the operation of the series capacitor in a single-phase PV system




Fig.1: Equivalent transformation of the current control loop with virtual capacitor concept

### B. DC COMPONENT MINIMIZATION IN THREE-PHASE PV INVERTERS WITH DC-COMPONENT FEED-FORWARD AND PIR CONTROLLERS

Based on the above analysis, this section investigates how to implement the “virtual capacitor” concept for three-phase systems in the stationary frame and to be further integrated to the standard PV inverter current control loop in the dq frame with a PIR controller.

The standard three-phase inverter current loop normally adopts a proportional-integral (PI) controller in the dq frame to regulate the d-axis and q-axis currents. The PI controller in dq frame is equivalent to a proportional-resonant (PR) controller in the stationary abc frame, given the resonant frequency of the R controller is selected as the line frequency (rotational frequency). Therefore, the current

control loop of three-phase inverters with blocking capacitors in stationary abc frame, where the variables with the subscript abc denote the vectors of the three-phase voltages and currents. The gain of the pulse width modulator (K<sub>PWM</sub>) is assumed to be unity to simplify the derivation. The PR controller is effectively a proportional (P) controller if only the dc component is taken into account, and the diagram for the dc component, where the variables with the subscript abc0 denote the vectors of the three-phase dc components. If the

# International Journal of Advanced Research in Electrical, Electronics and Instrumentation Engineering

(An ISO 3297: 2007 Certified Organization)

Website: [www.ijareeie.com](http://www.ijareeie.com)

Vol. 6, Issue 2, February 2017

capacitor voltage feedback terminal ( $1/C_s$ ) is moved to the feedback path, where  $K_P$  is the proportional gain, the physical blocking capacitor  $C$  can then be replaced with an integral and a feed-forward term (algorithm). Thus, the virtual capacitors are achieved in a three-phase PV system in the stationary a-b-c frame. To achieve the zero steady-state error for the dc component,

replaces the P controller) with an integral (I) controller. Then, in order to apply the dc component minimization method to the standard dual closed-loop control system in a synchronous frame, is then transformed to a mixed abc and dq frame. The reference current  $i_{abc0}^*$ , the grid voltage  $e_{abc0}$ , and the current controller is implemented in synchronous frame ( $i_{dq1}^*$ ,  $e_{dq1}$ , and the R controller, respectively). The “virtual capacitor” in the feedback path is still implemented in the stationary a-b-c frame.

### C. DC COMPONENT EXTRACTION BASED ON SLIDING WINDOW ITERATION

In the control strategy shown in Fig. 2, an accurate dc component measurement and extraction is the key to implement the virtual capacitor concept and achieve the overall dc component minimization. Compared with the ac component, the dc component is very small and an accurate dc component extraction is challenging. In PV inverters, the Hall-effect current sensors are widely used to measure the ac-side currents (including both ac and dc components) due to their smaller size, isolated output, and wide bandwidth (e.g., from dc to several hundred kilohertz). In this paper, an integral method based on the sliding window iteration algorithm is used to accurately extract the dc component from the ac-side currents.




Fig 2: DC component minimization strategy based on dc component feed-forward and PIR controllers.

on the sliding window iteration algorithm is used to accurately extract the dc component from the ac-side currents.

Taking the ac-side Phase A current  $i_a$ , for example,  $i_a$  can be expressed as in (1) if considering both the dc component and other ac components of different frequencies (e.g., harmonics)

$$i_a = i_{a0} + \sum_{h=1,2,3,\dots} I_h \sin(2\pi h f_1 t + \phi_h) \quad (1)$$

where  $i_{a0}$  is the dc component,  $f_1$  is the line frequency.  $I_h$ ,  $h f_1$ , and  $\phi_h$  are the amplitude, frequency, and phase angle of the fundamental and harmonic components. Averaging the integration of (1) in the interval from  $t_0$  to  $t_0 + T$  yields



# International Journal of Advanced Research in Electrical, Electronics and Instrumentation Engineering

(An ISO 3297: 2007 Certified Organization)

Website: [www.ijareeie.com](http://www.ijareeie.com)

Vol. 6, Issue 2, February 2017

$$\frac{1}{T} \int_{t_0}^{t_0+T} i_a dt = \frac{1}{T} \left[ \int_{t_0}^{t_0+T} i_{a0} dt + \int_{t_0}^{t_0+T} \sum_{h=1,2,3\dots} I_h \sin(2\pi h f_1 t + \varphi_h) dt \right] \quad (2)$$

When  $T = T_1 = 1/f_1$ , the second term in the right side of (2) becomes

$$\int_{t_0}^{t_0+T_1} \sum_{h=1,2,3\dots} I_h \sin(2\pi h f_1 t + \varphi_h) dt = 0. \quad (3)$$

Hence, with (2) and (3), the dc component  $i_{a0}$  can be obtained by

$$i_{a0} = \frac{1}{T_1} \int_{t_0}^{t_0+T_1} i_a dt. \quad (4)$$

The next step is to implement the expression in (4) to obtain the dc component  $i_{a0}$  accurately without significant calculation

burden. If assuming the number of sampling times in a fundamental period ( $T_1$ ) is  $N$ ,  $dt$  in (4) can be substituted by the sampling interval  $t$  and  $t = T_1/N$ . If  $\tau$  is defined as  $t/N$ , then  $i_a(k\tau)$  is the  $k$ th sampling value. Substituting the definite integration in (4) by the accumulation of the integrand, the discrete expression of  $i_{a0}$  is given by

$$i_{a0} = \frac{1}{N\Delta t} \sum_{k=0}^{N-1} i_a(k\tau)\Delta t = \frac{1}{N} \sum_{k=0}^{N-1} i_a(k\tau). \quad (5)$$

To achieve a real-time dc component extraction, (5) should accumulate the sampling values for  $N-1$  times in one fundamental period. The amount of calculation is therefore significant given a high sampling frequency. To decrease the amount of calculation, sliding window iteration is used in (6) to replace (5)

$$i_{a0} = \frac{1}{N} \sum_{k=N_{cur}-N+1}^{N_{cur}} i_a(k\tau) = \frac{1}{N} \sum_{k=N_{cur}-N}^{N_{cur}-1} i_a(k\tau) - i_a[(N_{cur}-N)\tau] + i_a(N_{cur}\tau) \quad (6)$$

where  $N_{cur}$  is the sliding pointer which represents the current

sampling point. After completing the summation of one fundamental period for initialization,  $N-1$  additions of (5) is simplified as one addition and one subtraction of (6). As a result, the amount of calculation is reduced.

### C. PIR CONTROLLER DESIGN

As mentioned, when taking the dc component in the ac-side currents into account, the current loop in the  $dq$  frame is composed of both a dc component and a line-frequency component (negative sequence). The dc component in the

# International Journal of Advanced Research in Electrical, Electronics and Instrumentation Engineering

(An ISO 3297: 2007 Certified Organization)

Website: [www.ijareeie.com](http://www.ijareeie.com)

Vol. 6, Issue 2, February 2017

rotational frame comes from the line-frequency ac components in the phase currents. The line-frequency component in the rotational frame




Fig. 3.  $d$ -axis current control loop based on the PIR controller

comes from the dc component in the phase currents. To provide an effective control for both dc and line-frequency signals in the  $dq$  frame, a proportional-integral-resonant (PIR) controller is used. Taking the  $d$ -axis current control loop, for example, considering the sampling delay and the PWM delay, the current control loop based on the PIR controller is shown in Fig.3

where  $T_s$  is the sampling period,  $K_p$  is the proportional gain,  $K_i$  is the integral gain, and  $K_r$  is the resonant gain.  $\omega_1$  is the resonant (center) frequency of the R controller, which is the same as the line frequency in this case.  $\omega_c$  is the cutoff frequency of the R controller to reduce the sensitivity against the slight frequency variations.

In Fig. 3, the PI controller is used to regulate the dc component transformed from the fundamental currents. The R controller is used to regulate and minimize the line-frequency component transformed from the dc component. The parameters of the PI controller should be set to guarantee a good dynamic and steady-state performance of the current loop. The parameters of the R controller are set for the dc component minimization.

An infinite gain at the resonant frequency of the R controller can eliminate the steady-state error. In the improved R controller with  $2\omega_c$  added to the denominator as shown in Fig. 3, the gain at the resonant frequency is limited yet with improved performance under line-frequency fluctuation. Nevertheless, the gain can be adjusted by  $K_r$ . Regarding  $\omega_c$ , smaller  $\omega_c$  provides better frequency selectivity but difficult for digital implementation. Larger  $\omega_c$  leads to a wider bandwidth around the resonant frequency and a better robustness for the frequency deviation. However, the gain at the resonant frequency will be lower with a subsequent larger steady-state error.

## IV. SIMULATION RESULTS




Fig 4: Grid current waveforms with DC component

# International Journal of Advanced Research in Electrical, Electronics and Instrumentation Engineering

(An ISO 3297: 2007 Certified Organization)

Website: [www.ijareeie.com](http://www.ijareeie.com)

Vol. 6, Issue 2, February 2017




Fig 5: Minimized dc component of Grid current waveforms by single integral




Fig 6: Minimized dc component of Grid current waveforms by double integral.




Fig 7: THD = 9.06%



# International Journal of Advanced Research in Electrical, Electronics and Instrumentation Engineering

(An ISO 3297: 2007 Certified Organization)

Website: [www.ijareeie.com](http://www.ijareeie.com)

Vol. 6, Issue 2, February 2017

## V. EXTENSION WITH FUZZY CONTROLLER




Fig 8: Minimized dc component of Grid current waveforms by single integral with fuzzy controller



Fig 9: Minimized dc component of Grid current waveforms by double integral with fuzzy controller




Fig 10: THD = 7.00%



# International Journal of Advanced Research in Electrical, Electronics and Instrumentation Engineering

(An ISO 3297: 2007 Certified Organization)

Website: [www.ijareeie.com](http://www.ijareeie.com)

Vol. 6, Issue 2, February 2017

## VI. CONCLUSION

This project has presented an effective method to minimize the dc component in a three-phase Transformerless grid-connected PV system. The dc component can introduce line-frequency power ripple in the system and further cause dc-link voltage ripple and second-order harmonics in the ac currents. A “virtual capacitor” approach has been implemented to minimize the dc component via a feed-forward of the dc component. The dc component can be accurately obtained using the sliding window iteration and double time integral even under frequency variation and harmonic conditions. A PIR controller has been designed to enable the precise regulation of both the dc and line-frequency components in the d-q frame.

The proposed method can be well adopted in the existing PV systems for dc component minimization using the sliding window iteration and double time integral even under frequency variation and harmonic conditions for dc-component extraction and Minimization of dc-component feed forward term as well as the resonant controller in the current control loops.

## REFERENCES

- [1] R. Gonzalez, E. Gubia, J. Lopez, and L. Marroyo, “Transformerless single-phase multilevel-based photovoltaic inverter,” *IEEE Trans. Ind. Electron.*, vol. 55, no. 7, pp. 2694–2702, Jul. 2008.
- [2] S. B. Kjaer, J. K. Pedersen, and F. Blaabjerg, “A review of single-phase grid-connected inverters for photovoltaic modules,” *IEEE Trans. Ind. Appl.*, vol. 41, no. 5, pp. 1292–1306, Sep./Oct. 2005.
- [3] E. Koutroulis and F. Blaabjerg, “Design optimization of transformerless grid-connected PV inverters including reliability,” *IEEE Trans. Power Electron.*, vol. 28, no. 1, pp. 325–335, Jan. 2013.
- [4] B. Gu, J. Dominic, J. Lai, C. Chen, T. LaBella, and B. Chen, “High reliability and efficiency single-phase transformerless inverter for grid-connected photovoltaic systems,” *IEEE Trans. Power Electron.*, vol. 28, no. 5, pp. 2235–2245, May 2013.
- [5] S. V. Araujo, P. Zacharias, and R. Mallwitz, “Highly efficient single-phase transformerless inverters for grid-connected photovoltaic systems,” *IEEE Trans. Ind. Electron.*, vol. 57, no. 9, pp. 3188–3128, Sep. 2010.
- [6] O. Lopez, F. D. Freijedo, A. G. Yepes, P. Fernandez-Comesaa, J. Malvar, R. Teodorescu, and J. Doval-Gandoy, “Eliminating ground current in a transformerless photovoltaic application,” *IEEE Trans. Energy Convers.*, vol. 25, no. 1, pp. 140–147, Mar. 2010.
- [7] V. Salas, E. Ol'ias, M. Alonso, and F. Chenlo, “Overview of the legislation of DC injection in the network for low voltage small grid-connected PV systems in Spain and other countries,” *Renewable Sustainable Energy Rev.*, vol. 12, no. 2, pp. 575–583, Feb. 2008.
- [8] B. Wang, X. Guo, H. Wu, Q. Mei, and W. Wu, “Real-time DC injection measurement technique for transformerless PV systems,” in *Proc. IEEE 2nd Int. Symp. Power Electron. Distrib. Generation Syst.*, Hefei, China, Jun. 2010, pp. 980–983.
- [9] W. Li, L. Liu, T. Zheng, G. Huang, and S. Hui, “Research on effects of transformer DC Bias on negative sequence protection,” in *Proc. Int. Conf. Adv. Power Syst. Automat. Protection*, Beijing, China, Oct. 2011, pp. 1458–1463.
- [10] A. Ahfock and A. J. Hewitt, “DC magnetisation of transformers,” *IEE Proc.-Electr Power Appl.*, vol. 153, no. 4, pp. 601–607, Jul. 2006.
- [11] M. A. S. Masoum and P. S. Moses, “Impact of balanced and unbalanced direct current bias on harmonic distortion generated by asymmetric three-phase three-leg transformers,” *IET Electr. Power Appl.*, vol. 4, no. 7, pp. 507–515, Jul. 2010.
- [12] F. Berba, D. Atkinson, and M. Armstrong, “A review of minimization of output DC current component methods in single-phase grid-connected inverters PV applications,” in *Proc. 2nd Int. Symp. Environ. Friendly Energies Appl.*, Tyne, U.K., Jun. 2012, pp. 296–301.
- [13] M. Armstrong, D. J. Atkinson, C. M. Johnson, and T. D. Abeyasekera, “Auto-calibrating DC link current sensing technique for transformerless, grid connected, H-bridge inverter systems,” *IEEE Trans. Power Electron.*, vol. 21, no. 5, pp. 1385–1393, Sep. 2006.
- [14] F. Berba, D. Atkinson, and M. Armstrong, “Minimization of DC current component in transformerless Grid-connected PV inverter application,” in *Proc. 10th Int. Conf. Environ. Elect. Eng.*, Rome, Italy, May 2011, pp. 1–4.
- [15] Y. Shi, B. Liu, and S. Duan, “Eliminating DC current injection in current-transformer-sensed STATCOMs,” *IEEE Trans. Power Electron.*, vol. 28, no. 8, pp. 3760–3767, Aug. 2013.
- [16] G. Buticchi, E. Lorenzani, and A. Fratta, “A new proposal to eliminate the DC current component at the point of common coupling for grid connected systems,” in *Proc. IEEE 36th Ann. Conf. Ind. Electron. Soc.*, Glendale, USA, Nov. 2010, pp. 3244–3249.
- [17] T.-F. Wu, H.-S. Nien, H.-M. Hsieh, and C.-L. Shen, “PV power injection and active power filtering with amplitude-clamping and amplitude-scaling algorithms,” *IEEE Trans. Ind. Appl.*, vol. 43, no. 3, pp. 731–741, May/Jun. 2007.
- [18] W. M. Blewitt, D. J. Atkinson, J. Kelly, and R. A. Lakin, “Approach to low-cost prevention of DC injection in transformerless grid connected inverters,” *IET Power Electron.*, vol. 3, no. 1, pp. 111–119, Jan. 2010.